

MATERIAL SAFETY DATA SHEET – L84

SECTION I: CHEMICAL PRODUCT AND COMPANY IDENTIFICATION	
<p>PRODUCT IDENTITY: "Battery, Electric Storage, Wet, Nonspillable, Not Regulated". NONSPILLABLE Absorbed Electrolyte Battery – Electrical Storage Valve Regulated Lead-Acid (VRLA) Battery – Absorbed Glass Mat (AGM) Date issued: Sept. 28, 1986</p>	
<p>Manufacturer Name: C&D Technologies, Inc. Address: 1400 Union Meeting Road P.O. Box 3053 Blue Bell, PA 19422-0858</p>	<p>Telephone numbers: Day time: 215-619-2700 Toll Free: 800-543-8630</p>
<p>Web site: www.cdtechno.com North America 24 Hour Emergency Telephone: (CHEM TEL) 1-800-255-3924 International 24 Hour Emergency Telephone: (CHEM TEL) 1-813-248-0585</p>	

SECTION II: COMPOSITION / INFORMATION ON INGREDIENTS				
HAZARDOUS OSHA COMPONENT	<u>CAS#</u>	<u>OSHA PEL</u>	<u>ACGIH TLV</u>	<u>% BY WEIGHT</u>
* Sulfuric Acid / Battery Electrolyte 1.300 sg 40 wt %	7664-93-9	1mg/m ³	1mg/m ³ STEL	22
*Lead/Grid	7439-92-1	50 ug/m ³	150 ug/m ³	50
*Lead Oxide/Dioxide	1309-60-0	50 ug/m ³	150ug/m ³	21
*Lead Sulfate/ Anglesite	7446-14-2	50ug/m ³	150ug/m ³	<1
Section 313 (40 CFR 372) Listed Toxic Chemicals are Preceded by an*				

SECTION III: HAZARDOUS IDENTIFICATION	
<p>Appearance and Odor: Acid is a clear to cloudy liquid. Lead is metallic gray in color. Formed lead dioxide is a dark brown in color with a slight acidic odor.</p> <p>Routes of entry: Sulfuric Acid: Inhalation, skin, ingestion. Lead: Inhalation and Ingestion. Ingestion of lead occurs by hand to mouth contamination. After handling lead or its compounds, hands must be washed prior to eating or drinking. Metallic lead cannot be absorbed through the skin.</p>	<p>Health Hazards (Acute & Chronic) Acute: Sulfuric acid exposure may cause irritation of the skin, corneal damage of the eyes, irritation of the mucous membranes and upper respiratory system, including the lungs. Acute lead exposure may cause GI upset, loss of appetite, diarrhea, constipation, fatigue, joint pain, and difficulty sleeping. Chronic: Exposure to lead may cause anemia, kidney damage and damage to the central nervous and reproductive systems. Lead exposure may also affect developing fetuses in pregnant women. Chronic exposure to sulfuric acid may cause scarring of skin and mucous membranes, bronchitis, contact dermatitis, and erosion of tooth enamel.</p>
<p>HMIS label rating for sulfuric acid: Health: 3 Flammability: 0 Reactivity: 2 Other: 0</p>	

SECTION III (Continued)	
<p>NFPA label rating for sulfuric acid: Health: 3 Flammability: 0 Reactivity: 2 Other: 0 Sulfuric acid is water-reactive if concentrated.</p>	<p>Rating Codes: 0= Insignificant, 1= Slight, 2= Moderate, 3= High, 4= Extreme</p>
<p>HMIS and NFPA Hazard labels are used to identify the battery(s) dilute 1.300sg sulfuric acid. The first number represents the Health hazard, second number represents Fire hazard, and the third number represents the Reactivity hazard. The fourth space identifies the hazardous material, which is acid and/or typical recommended personal protective equipment, i.e., safety glasses, rubber or neoprene gloves etc.</p>	
<p>California Proposition 65 Warning – Battery posts, terminals, and related accessories contain lead and lead compounds, chemicals known to the State of California to cause cancer and reproductive harm. Batteries also contain other chemicals known to the State of California to cause cancer. Wash hands after handling.</p>	

SECTION IV: FIRST AID PROCEDURES – Sulfuric Acid	
<u>Skin/Eyes</u>	<u>Ingestion/Inhalation</u>
<ul style="list-style-type: none"> - Flush the affected area with water for 15 minutes - Remove contaminated clothing - If irritation continues, seek medical attention 	<ul style="list-style-type: none"> - Do not induce vomiting - Drink 8 oz. of water or milk - If difficulty in breathing occurs, remove to fresh air, give CPR if necessary - Seek medical attention immediately

SECTION V: FIREFIGHTING MEASURES
<p>FIRE AND EXPLOSIVE PROPERTIES:</p> <p>Hydrogen Flash point: -259°C Hydrogen Autoignition point: 580°C Hydrogen Flammable Limits in Air (% by Volume): LEL: 4.1 UEL: 74.2 Lower Explosion Limit (LEL), Upper Explosion Limit (UEL)</p> <p>Unusual Fire and Explosion Hazards: Hydrogen and Oxygen gases are produced in cells during normal battery operation. Ventilate Area.</p> <p>Extinguishing Media: Dry Chemical, Foam or CO₂</p> <p>Special Firefighter Procedures: Use Positive Pressure, self-contained breathing apparatus.</p>

SECTION VI: ACCIDENTAL RELEASE MEASURES
<p>STEPS TO BE TAKEN IF BATTERY IS BROKEN: Neutralize exposed battery parts with soda ash or sodium bicarbonate until fizzing stops, pH should be at neutral 6-8. Provide adequate ventilation. Heat, carbon dioxide and hydrogen gas may be given off during neutralization. Collect residue in a suitable container. Place the broken battery in a heavy-duty plastic bag or other non-metallic container. Properly recycle all battery residue and parts.</p>

SECTION VII: HANDLING AND STORAGE
<p>Store in a cool; dry area away from combustibles. Do not store in sealed, unventilated areas. Avoid overheating and overcharging. Do not use organic solvents or other than manufactures recommended cleaners on the batteries.</p>

SECTION VIII: EXPOSURE CONTROLS/PERSONAL PROTECTION

Engineering Controls: General room ventilation is sufficient during normal use and handling. Do not install these batteries in a sealed, unventilated area.

PERSONAL PROTECTIVE EQUIPMENT (DURING INSTALLATION OR IN THE EVENT OF BATTERY BREAKAGE)

Eye Protection = Chemical goggles, safety glasses with sideshields and or a full-face shield.

Protective gloves = Rubber or neoprene

Respiratory Protection = NIOSH approved acid mist/organic vapor respirator, if OSHA PEL is exceeded.

Other Protective Equipment = Acid resistant apron or clothes.

WORK PRACTICES: Use standard lead-acid battery practices. Do not wear metallic jewelry when working with batteries. Use non-conductive tools only. Discharge static electricity prior to working on a battery. Maintain eyewash, fire extinguisher and emergency communication device in the work area.

SECTION IX: PHYSICAL AND CHEMICAL PROPERTIES

ACID : Boiling Point: 110°C to 112°C	Vapor Pressure: 13.8 mm Hg @ 25°C
Vapor Density: (Air=1) 3.4	Melting point: N/A
Solubility in water: N/A	
Specific Gravity 1.300 +/- 0.030	
Appearance/Odor: clear to cloudy with slightly acidic odor	

SECTION X: STABILITY AND REACTIVITY

STABILITY: This battery and contents are stable.

Conditions to avoid: Overheating, overcharging which results in acid mist/Hydrogen generation.

Incompatibility (materials to avoid): Strong alkaline materials, conductive metals, organic solvents, spark or open flame.

Hazardous Byproducts: Hydrogen gas may be generated in an overcharged condition, in fire or at very high temperatures. In fire, may emit CO, CO₂ and Sulfur Oxides.

Hazardous polymerization will not occur

SECTION XI: TOXICOLOGICAL INFORMATION – SULFURIC ACID			
The C&D VRLA batteries are a sealed, recombinant design that require no water replacement throughout their service life, thus no contact is made with the battery's internal components or chemical hazards. Under normal use and handling, these batteries do not emit regulated or hazardous substances.			
	Administration Route	Dose	Test Animal
LD 50	Oral	2140 mg/kg	Rat
LDLo	Unreported	135 mg/kg	Man
LC50	Inhalation	510mg/m3	Rat
Carcinogenicity: The International Agency on Cancer (IARCC) has classified “strong inorganic acid mists containing sulfuric acid” as a category 1 carcinogen (inhalation), a substance that is carcinogenic to humans. This classification does not apply to the liquid forms of sulfuric acid contained within the battery. Misuse of the product, such as overcharging, may result in the generation of sulfuric acid mist at high levels.			

SECTION XII: ECOLOGICAL INFORMATION
Lead and its compounds can pose a threat if released into the environment.

SECTION XIII: DISPOSAL CONSIDERATIONS
Waste Disposal Method: Send to lead smelter for reclamation following applicable Federal, State and Local regulations. Product can be recycled along with automotive (SLI) lead-acid batteries.

SECTION XIV: TRANSPORTATION AND INTERNATIONAL REGULATIONS
All C&D AGM batteries, when transported by air, surface or by vessel are identified as “ Battery, Electric Storage, Wet, Nonspillable, Not Regulated ”.
The battery(s) must be identified as above on the Bill of Lading and properly packaged with their terminals protected from short circuit. <u>NA or UN numbers do not apply.</u>
C&D AGM battery(s) warning label identifies each battery as NONSPILLABLE.
C&D AGM battery(s) preprinted cartons identifies each battery as NONSPILLABLE.
C&D AGM battery(s) shipped without cartons (bulk packed) need to be Identified as NONSPILLABLE or NONSPILLABLE BATTERY on the outer packaging.
Air: C&D AGM batteries meet the conditions in IATA/ICAO Special Provision A67.
Surface: C&D AGM batteries meet the conditions for DOT Haz Mat Regulations CFR-Title 49 parts 171-189.
Vessel: C&D Batteries meet the conditions of IMDG exception 238.

SECTION XV: REGULATORY INFORMATION
See 29 CFR 1910.268(b)(2)

SECTION XVI: OTHER INFORMATION
The information herein is given in good faith, but no warranty, expressed or implied, is made.

MSDS Preparation / Review Date: 10/18/2010 Revision: 12
 Prepared by: W. Kozlowski